


ADDENDUM TO CONTRACT DOCUMENTS

| | |
|--|--|
|  The logo for Solano Community College features a green vine with leaves inside a blue semi-circular arch with horizontal lines. Below the arch, the word "SOLANO" is written in a large, blue, serif font, and "COMMUNITY COLLEGE" is written in a smaller, blue, sans-serif font below it. | ADDENDUM: #01 |
| | BID: #14-011A |
| | Project: South Parking Lot Electrical Interconnection(Re-Bid) |
| | Date: 05/29/2014 All Addenda can be found at the District Purchasing website: www.solano.edu/purchasing |

To All Prospective Bidders:

This **ADDENDUM**, dated ***May 29, 2014*** supersedes the original PROJECT MANUAL and DRAWINGS and previous Addenda, wherein it contradicts them. All other conditions remain unchanged.

Acknowledgment of receipt of this **ADDENDUM** is required on Bid Form.

Answers to Specific Questions:

1. Can the pullbox be relocated out of the traffic lanes and into the parking lot?
Located on Sheet E1.4a Keynote #2.
Answer: Adjust pullbox location in field to clear existing underground utilities, and other obstructions. Pullbox shall not be placed in the parking lot.