

## ADDENDUM TO RFP DOCUMENTS

 <b>SOLANO</b> COMMUNITY COLLEGE 	ADDENDUM #02
	Project: Solano Community College District Softball Bleacher Replacement Project
	Date: January 16, 2017

The following clarifications are provided based on questions received or changes in District requirements and must be added/considered when completing your submittal: Acknowledgement of receipt of this **ADDENDUM** is required in the proposal's cover letter of introduction. Please clearly note the addendum date and number.

### ITEM:

#### **ITEM NO. 1 – Answers to Submitted Questions**

**QUESTION** - I have received Addendum 1 and noted the additional alternates added to the bid form. Will the method of award remain to be based on sum of Base Bid and Alternate #1 or will the awarding include the sums of Alternates #2 and #3 as well. Please clarify.

**ANSWER** – The Project will still be awarded based on the cumulative sum of the BASE BID and Add Alternate #1.

**QUESTION** – Note 4 on Sheet C2 notes the existing conduits underneath the existing press box to be extended to the new location of the press box. There is no electrical spec regarding this work. Please provide.

**ANSWER** – See “ELECTRICAL NOTES” on upper right corner of Sheet C2.

**QUESTION** – Para 2.03.B.2i of spec section 13125 states that the service line from the press box to the conduit will be the owner's responsibility. Please confirm.

**ANSWER** – Disregard the statement “(Service line to Press Box is responsibility of Owner)”. Contractor shall include in their proposal all boxes, conduits, fittings, accessories and wiring for service to press box from existing conduit. See construction plans for additional requirements that may be necessary.